

# TEPA HSE AWARDS 2019



FULL NAME: Emmerson WATHA

COMPANY / ENTITÉ: SONADIETS

SITE: FPSO PAZFLOR

METIER / JOB POSITION: ICSS SPV

DATE: 04/03/2018

TEPA ORGANIC

CONTRACTOR

STOP CARD USED

**SAFETY +**  
by TOTAL

BEST ANOMALY

BEST PRACTICE / INITIATIVE

BEST BEHAVIOUR / ACT

## Short Description:

Found the water mist of FWP-A inhibited one day after job finished.

## Obtained result:

In case of fire inside the package the active fire protection would not start. In addition, the FWP-A near the LQ (portside, AFT process deck), Good assessment and action taken to reactive the auto mode of fire fighting.

## RELATED GOLDEN RULES

-  RISK SITUATIONS
-  TRAFFIC
-  BODY MECHANICS AND TOOLS
-  PROTECTIVE EQUIPMENT
-  WORK PERMITS
-  LIFTING
-  WORK ON POWERED SYSTEMS
-  CONFINED SPACES
-  EXCAVATION WORK
-  WORK AT HEIGHT
-  CHANGE MANAGEMENT
-  SIMOPS OR CO-ACTIVITIES

# ARGUMENT

(BY RSES / CHEF OF DIVISION / DIRECTOR / HSE MANAGER / HSE SUPERVISOR / OTHERS)

## Detailed Description

Inhibition is one of precaution that is required and implemented in some particular cases, to perform a job on powered systems. it is the case when people work inside the package for preventive maintenance (PM), functional test and troubleshooting, normally done by electrical, mechanical, instrumentation and production teams.

During is walk around on his way back to LQ he noticed that the water mist was inhibited. after checking with control room whether any work was being carried out in the package and checking that there was no issue with the system, he removed the water mist inhibition.

This anomaly clearly demonstrate that people on board are vigilante and sort out risky situations.

Emerson is a system (PLC) engineer.

## Illustrations (Pictures, infographics, schemes)

**OBSERVATION CARD**

Anomaly  Good practice

Date: 04/03/2018 Location/Site: FWPA / LQ

Anomaly / Good practice identified: Find Fire Water Pump A. Water mist inhibited since 03/03/2018 at 9h34

Immediate actions implemented: Inform CCR, make look inside if Person involve and Put back to auto → Inform again CCR

Observer's name or Department: EMERSON WATHA B. M / JCS PLL

Action implemented: With CCR accordance Put back in auto

Signature: [Signature] Date: 04/03/2018 Supervisor in charge's name: EMERSON WATHA B. M

